

XP & STS Series Electrical Requirements

XP Series Beds


Model Bed	2400XP	2800XP	3200XP
Amperage Drawn	14	16	18
Circuit Needed	20	20	30
Required Voltage	230	230	230
Required Receptacle	nema 6-20	nema 6-20	nema 6-30

STS 160w Series Beds

Model Booth	8000sts	9000sts
Lamps	48-160w	56-160w
Amperage Drawn	47	55a
Circuit Needed	60a	70a
Required Voltage	230	230
Required Receptacle	hardwire	hardwire



Nema (6-20) Outlet



Nema (6-30) Outlet